From

Director, Urban Local Bodies-cum-Fire Service, Haryana. Bays No. 11-14, Sector-4, Panchkula.

To

- 1. All the Commissioners of Municipal Corporations in the State of Haryana.
- 2. All the Deputy Commissioners in the State of Haryana.
- 3. The Executive Officers/Secretaries, of all Municipal Councils/Committees in the State of Haryana.
- 4. The Secretaries of Market Committees in the State of Haryana (where Fire Station Exists).
- 5. Fire Station Officers/In-charges, all Fire Stations in the State of Haryana.

Memo No: DFS/FA/2017/ Dated:

## Subject:

Regarding revision of checklist as per National Building Code of India-2016, required for approval of fire-fighting scheme under section 15 of the HFS Act. 2009.

Reference on the subject cited above.

- The revised checklist as per National Building Code of India-2016, required for approval of fire-fighting scheme under section 15 of the HFS Act. 2009 and specimen Declaration /Affidavit to be submitted by the Architect / Owners of the Building are enclosed herewith.
- You are requested to take further necessary action in the matter in future accordingly.

Deputy Director (Tech-1), for Director, Urban Local Bodies-cum-Fire Service, Haryana, Panchkula.

Endst. No. DFS/FA/2017/ 65278

Dated:

A copy of the above is forwarded to the Chief Town Planner, HQ for information and further necessary action.

Deputy Director (Tech.-1), for Director, Urban Local Bodies-cum-Fire Service, Haryana, Panchkula.

## CC: -

- 1. PA/DFS
- 2. ATP- Nodal Officer, HEPC
- 3. Web-Portal

## PERFORMA FOR HARYANA FIRE SERVICE

1. Name & address of the building

2. Type of Occupancy :

3. No. of Blocks/ Towers :

4. Height of the Building :

5. Permissible Height :

6. Number of floors :

7. Covered area at ground floor

8. Typical floor area/ area at each floor :

9. No. of Basements

10. Basement floor area, if any :

11. Total plot area :

12. Check list according to HFS Act 2009/HBC-2017/NBC -2016

S. No.	Minimum standards on fire prevention and fire safety (Clause/Code/BIS)	HBC-2017 / NBC- 2016 requirement	Provisions proposed	
1	Access to fire appliances (4.6/ NBC-3)			
	Road width			
	Gate width			
	Width of internal road			
	Remarks. if any:			
2.	Size (width) Number, type & arrangement of exits			
	Travel distance (4.4.2.2/ NBC-4))			
	Dead end travel distance (4.4.2.2 (C))			
	Number of staircases (4.4.2.1/ NBC-4)			
	Upper floors			
	Basements			
	Width of staircases (4.4.2.4.3.2/ NBC-4)			
	Upper floors			
	Basements			
	Provisions of Staircase (4.4.2.4.3/ NBC-4)			
	Firefighting Shaft/Fire Tower (2.24 & E2/NBC-4)			
	No. Of continuous staircases to terrace			
	[4.4.2.4.3.2-h4/ NBC-4]			
	Ramp, if any (width ) (4.4.2.4.3.5/ NBC-4)			
	Protection of exits(4.4.2.5/ NBC-4))			
	• Fire check door (4.4.2.4.3.2-h2/ NBC-4]			
	• Pressurization (4.4.2.5(b)& E2/ NBC-4)			
	Width of Corridor (4.4.1 & 4.4.2.4.2 / NBC-4)			
	Door Size (4.4.2.4.1/ NBC-4)			
	Remarks. if any:			
	The state of the s			

3.	Compartmentation (4.5/ NBC-4)					
	<ul> <li>No. of fire compartments at basement</li> </ul>					
	level					
	Type of compartmentation					
	a) By fire resisting wall of 02 hrs rating	Yes / No				
	b) By fire curtain of 02 hrs rating	Yes / No				
	c) By water curtain	Yes / No				
	Fire check door					
	Remarks. if any:					
4.	Smoke management system (3.4.8, 4.6/ Annex F I	NBC-4)				
	Mechanical/ Natural					
	Basements air changes (12ACPH )					
	<ul> <li>Upper floors air changes(12ACPH)</li> </ul>					
	Remarks, if any					
5.	Fire Extinguishers (5.1 / NBC-4/IS 2190)					
٥.	Total numbers on each floor					
	Remarks. if any:					
	Nemarks. If any.					
6.	First-aid Hose Reels (5.1 / NBC-4/IS 884)					
	Total number on each floor					
	Remarks. if any:					
7	Automobile File Data visus and All visus and					
7.	Automatic Fire Detection and Alarming system(4.	9/ NBC-4/IS 2189)				
	Type of Detectors					
	Above false Ceiling. if any Remarks. if any:	ALTA TARANTA AND AND AND AND AND AND AND AND AND AN				
	Remarks. If any:					
8.	MOEFA (4.9/ NBC-4/IS 2189)					
9.	Public Address System (3.4.12/ NBC-4)					
10.	Automatic Sprinkler System (5.1.3/NBC -4/IS-1510	05)				
	Basement					
	Upper floor					
	Sprinkler above false ceiling					
	Fire Service inlet					
11.	Internal Hydrants (5.1/ NBC-4/ IS 3844)					
	Size of Riser/ Down comer					
100	Number of Hydrants per floor					
	Total no. of Hydrants in the premises					
	Hose boxes near landing valve					
	Fire Service inlet					
	Remarks. if any:					
12.	Yard Hydrants (5.1/ NBC-4/IS-13039)	HERE ELLEVISION AND AND AND AND AND AND AND AND AND AN				
	Total number of yard hydrants					
	Hose box					
	Remarks. if any:					

13.	Pumping arrangements (5.1.2.2/22&23 of table 7/NBC-4)					
	Ground Level					
	<ul> <li>Number of pump sets</li> </ul>					
	Discharge of main pump (LPM)					
	Head of main Pump     Number of main pumps					
	Head of Jockey Pump					
	Standby pump output (LPM)					
	Pressure at Terrace level					
	Direct access to Pump house from					
	ground level					
	Terrace level					
	Discharge of pump					
	Remarks. if any:					
14.	Captive water storage for firefighting (5.1.2.1/NBC-4/ IS 15105)					
	Underground tank capacity	- 47 10 101007				
	Draw off Connection					
	Fire Service Inlet					
	Access to tank					
	Overhead tank capacity					
	Remarks, if any					
15.	Exit signage (3.4.7/ NBC-4)					
16.	Provision of lifts (E-3/ NBC-4)					
	Fireman's lift switch					
	<ul> <li>Pressurization of lift shaft</li> </ul>					
	Pressurization of lift lobby					
	Remarks. if any:					
17.	Standby power supply (3.4.6.2, 3.4.6.4/ NBC-4)					
18.	Refuge area (E-4/NBC part-4)					
	• level					
	direct access to nearest staircase					
	Remarks. if any:					
19.	Fire Command Centre (3.4.12/NBC-4)					
	Proposed Location	Ground floor				
	Provision of fire safety officer (4.10/NBC-4)					
	Remarks. if any:					
20.	Provision of Helipad (E-8/NBC-4)					
21.	Special fire protection systems for					
	protection of special risks, if any 3.4.6, 3.4.9,					
	4.7, 4.8					
	(special risks-transformer/Sub-station, electrical					
	panel, petroleum products, boiler room, LPG /					
	PNG installation, lightning etc, if any)					

## DECLARATION

١,		, S	/W/D /o Sh		, the Architect of the
buildir				proposed	at (Location
solem	nly affirm and d	eclare as follows	:		
1. Tha	at I am duly regi	stered with		Building Aut	hority having registration
numbe	er	My office add	ress is		
and co	ontact Number i	s	-•		
2. Tha	t the aforesaid	building has been	planned and designe	ed strictly as per the	provisions of HBC-2017/
Nation	nal Building Cod	e of India.			
			the aforesaid building nd relevant code of st		d as per the provisions of
Signat	cure of Owner /	Occupier	Signature	of Architect	
Name	:		Name:		
			Stamp :		
Date	:				
Place	:	_			
		Verifi	ied by Local / Building	g Authority:	
	Name	:			
	Designation				
	Stamp				
Date	:	-			
Place	:	- 45 11			